
NATIONAL AERONAUTICS
AND SPACE ADMINISTRATION

NASA-10165 (June 2004)
NASA
Superseding NASA-10165
(March 2003)

SECTION TABLE OF CONTENTS

DIVISION 10 - SPECIALTIES

SECTION 10165

PLASTIC LAMINATE TOILET COMPARTMENTS

06/04

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DELIVERY, HANDLING, AND STORAGE
- 1.4 FIELD MEASUREMENTS
- 1.5 QUALITY ASSURANCE

PART 2 PRODUCTS

- 2.1 PLASTIC LAMINATE
- 2.2 CORE
- 2.3 USE OF RECOVERED MATERIALS
- 2.4 ADHESIVE
- 2.5 PILASTERS, SUPPORTS, AND HANGERS
- 2.6 ANCHORING DEVICES AND FASTENERS
- 2.7 HARDWARE AND FITTINGS
 - 2.7.1 Materials
 - 2.7.2 Finishes
- 2.8 BRACKETS
- 2.9 DOOR HARDWARE

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 CEILING-HUNG PARTITIONS
- 3.3 OVERHEAD-BRACED PARTITIONS
- 3.4 FLOOR-SUPPORTED PARTITIONS
- 3.5 WALL-MOUNTED PARTITIONS
- 3.6 SCREENS
 - 3.6.1 Entrance Screens
 - 3.6.2 Urinal Screens
- 3.7 FINAL ADJUSTMENTS AND INSPECTION
 - 3.7.1 Adjustment
 - 3.7.2 Inspection
- 3.8 ACCEPTANCE PROVISIONS
 - 3.8.1 Repairing
 - 3.8.2 Cleaning

-- End of Section Table of Contents --

NASA-10165 (June 2004)
NATIONAL AERONAUTICS NASA
AND SPACE ADMINISTRATION Superseding NASA-10165
(March 2003)

SECTION 10165

PLASTIC LAMINATE TOILET COMPARTMENTS 06/04

NOTE: Delete, revise, or add to the text in this section to cover project requirements. Notes are for designer information and will not appear in the final project specification.

This section covers laminated-plastic toilet partitions including partitions used as room entrances and urinal screens. It covers requirements for fabrication and installation of wall-mounted, overhead-braced, ceiling-hung, and floor-supported units.

Associated work found in other sections includes:

Shower and dressing compartments, toilet and bathroom accessories, structural supports, and floor finishes

Drawings must indicate:

Locations and dimensions of the partitions, doors, pilasters, screens, and door swings

Heights of the bottoms of enclosures and screens above the floor

Method of support to be employed, with details where needed for clarity

Provisions for attaching hardware to partitions

A schedule to identify the finish and color to be used

PART 1 GENERAL

1.1 REFERENCES

NOTE: The following references should not be manually edited except to add new references. References not used in the text will automatically be deleted from this section of the project specification.

The publications listed below form a part of this section to the extent referenced:

ALUMINUM ASSOCIATION (AA)

AA 45 (2003) Designation System for Aluminum Finishes

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

ANSI A208.1 (1993) Wood Particleboard

ASTM INTERNATIONAL (ASTM)

ASTM A 123/A 123M (2002) Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products

ASTM A 167 (1999) Standard Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip

ASTM A 336/A 336M (2003a) Standard Specification for Steel Forgings, Alloy, for Pressure and High-Temperature Parts

ASTM A 385 (2003) Standard Practice for Providing High-Quality Zinc Coatings (Hot-Dip)

ASTM B 221/B 221M (2003) Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes

ASTM B 36/B 36M (2001) Brass Plate, Sheet, Strip, and Rolled Bar

ASTM B 456 (2003) Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium

ASTM B 630 (1988; R 2001) Standard Practice for Preparation of Chromium for Electroplating with Chromium

ASTM D 4690 (1999) Standard Specification for Urea Formaldehyde Resin Adhesives

ASTM E 86 (1986) Zinc Base Alloy; Die Castings

HARDWOOD PLYWOOD & VENEER ASSOCIATION (HPVA)

HPVA HP-1 (2000) Standard for Hardwood and Decorative Plywood

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA LD 3 (2000) High-Pressure Decorative Laminates

NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (NIST)

NIST PS 1 (1995) Construction and Industrial Plywood

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

FS FF-B-588 (Rev D) Bolt, Toggle; and Expansion
Sleeve, Screw

FS FF-S-325 (Int Amd 3) Shield, Expansion; Nail,
Expansion; and Nail, Drive Screw (Devices,
Anchoring, Masonry)

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions
in Section 01330, "Submittal Procedures," and edit
the following list to reflect only the submittals
required for the project. Submittals should be kept
to the minimum required for adequate quality
control. Include a columnar list of appropriate
products and tests beneath each submittal
description.

The following shall be submitted in accordance with Section 01330,
"Submittal Procedures," in sufficient detail to show full compliance with
the specification:

SD-02 Shop Drawings

Fabrication drawings shall be submitted for toilet Partitions and
Urinal Screens consisting of fabrication and assembly details to
be performed in the factory.

Installation Drawings shall be submitted for toilet partitions and
urinal screens in accordance with the paragraph entitled,
"Installation," of this section.

SD-03 Product Data

Manufacturer's catalog data shall be submitted for the following
items:

Plastic Laminate
Core
Adhesive
Pilasters, Supports, and Hangers
Anchoring Devices and Fasteners
Hardware and Fittings
Brackets
Door Hardware

SD-04 Samples

Three of each item of Hardware and Fittings and Anchoring Devices and Fasteners.

Three 12-inch 300 millimeter square samples of Panels showing a finished edge on two adjacent sides and the core construction.

Three sets of the full color range of the Plastic Laminate.

When requested, full size models of Partitions and Screens, including pilasters, hardware and fasteners, anchoring and leveling devices, and accessories.

Approved Hardware and Fittings samples may be installed in the work if properly identified.

SD-07 Certificates

Product quality and manufacturer Certification shall be provided by the Contractor in accordance with paragraph entitled, "Quality Assurance," of this section.

1.3 DELIVERY, HANDLING, AND STORAGE

Items shall be delivered in the manufacturer's original unopened protective packaging. Materials shall be stored in a manner to prevent soiling, physical damage, or wetting. Materials shall be handled so as to prevent damage to finished surfaces.

1.4 FIELD MEASUREMENTS

Field measurements shall be taken prior to the preparation of drawings and fabrication to ensure proper fits.

1.5 QUALITY ASSURANCE

Certification that manufacturer is engaged in the manufacture of laminated plastic toilet partitions.

Certification that toilet partitions will be free of defects in materials, fabrication, finish, and installation and will remain so for a period of not less than [____] years after completion.

PART 2 PRODUCTS

2.1 PLASTIC LAMINATE

Plastic laminate shall conform to NEMA LD 3 and shall have a minimum thickness 0.062 inch 1.57 millimeter.

Plastic laminate shall be bonded to the core in one-piece sheets under continuous heat and pressure. No splices or joints shall exist in faces. Edges shall be sealed against moisture. Reinforcement for installation of hardware and fittings shall be concealed.

2.2 CORE

[Core shall be of particle board conforming to ANSI A208.1, Type 1.]

[Core shall be hardwood-faced plywood, birch, conforming to HPVA HP-1, Type 2, sound grade.]

NOTE: Use the following core material for urinal screens.

Core shall be softwood plywood, Douglas fir, conforming to NIST PS 1, Exterior, Grade A-B veneer.

2.3 USE OF RECOVERED MATERIALS

NOTE: Plastic or Steel shower and restroom dividers/partitions are one of the materials listed in the EPA's Comprehensive Procurement Guidelines (CPG) (<http://www.epa.gov/cpg/>). If the Architect/Engineer determines that use of certain materials meeting the CPG content standards and guidelines would result in inadequate competition, do not meet quality/ performance specifications, are available at an unreasonable price or are not available within a reasonable time frame, the Architect/Engineer may submit written justification and supporting documentation for not procuring designated items containing recovered material. Written justification may be submitted on a Request for Waiver Form to the NASA Environmental Program Manager for approval. The Request for Waiver Form is located in the NASA Procedures and Guidelines (NPG 8830.1) (<http://nodis3.gsfc.nasa.gov>).

[Steel] [Plastic] partitions shall have a recovered materials content [20-30 percent] [20-100 percent] in accordance with Environmental Protection Agency (EPA) recommendations.

2.4 ADHESIVE

Adhesive shall be urea resin conforming to ASTM D 4690.

2.5 PILASTERS, SUPPORTS, AND HANGERS

Pilasters, supports, and hangers shall be equipped with leveling devices, anchor studs, and locking nuts.

NOTE: Delete the following sentence for wall supported partitions if it is not required.

Pilaster shoes shall be one-piece, corrosion-resistant steel plinths hemmed top and bottom, formed to fit pilaster, and equipped with concealed clips.

2.6 ANCHORING DEVICES AND FASTENERS

Steel anchoring devices and fasteners shall be hot-dipped galvanized after fabrication in conformance with ASTM A 385 and ASTM A 123/A 123M.

Galvanized anchoring devices shall be concealed. Toggle bolts shall conform to FS FF-B-588. Masonry anchors shall conform to FS FF-S-325. Exposed fasteners shall have one-way heads.

2.7 HARDWARE AND FITTINGS

2.7.1 Materials

[Cold-rolled sheet steel shall conform to ASTM A 336/A 336M, commercial quality.]

[Zinc-base alloy shall conform to ASTM E 86, Alloy AC41-A.]

[Brass shall conform to ASTM B 36/B 36M, Alloy C26800.]

[Aluminum shall conform to ASTM B 221/B 221M]

[Corrosion-resistant steel shall conform to ASTM A 167, Type 302 or 304.]

2.7.2 Finishes

NOTE: Delete inapplicable paragraphs.

Chrome plating shall conform to ASTM B 456.

Finish shall conform to ASTM B 630, Class I, Type I or II.

Aluminum shall have a clear anodic coating conforming to AA 45.

Corrosion-resistant steel shall have a No. 4 finish.

Exposed fasteners shall match hardware and fittings.

2.8 BRACKETS

Wall brackets shall be two-ear panel brackets, T-style, 1-inch 25 millimeter stock.

Panel to pilaster brackets shall be stirrup style.

2.9 DOOR HARDWARE

Hinges shall be self-lubricating with the indicated swing.

Hinges shall be the [surface-mounted] [cutout-insert] type.

Hinges shall have the following type of return movement:

[Gravity] [Spring-action cam] [Torsion-rod] return movement

Hinges shall be adjustable to hold inswinging doors open at any angle up to 90 degrees and outswinging doors to 180 degrees.

Latch and pull shall be combination rubber-faced door strikes and keepers equipped with emergency access.

Coat hooks shall be combination units with hooks and rubber tipped pins.

PART 3 EXECUTION

3.1 INSTALLATION

Partitions shall be installed rigid, straight, plumb, and level with the panels centered between the fixtures. Contractor shall provide a panel clearance of not more than 1/2 inch 15 millimeter and shall secure the panels to walls and pilasters with not less than two brackets attached near the top and bottom of the panels. Wall brackets shall be located so that holes for wall bolts will occur in masonry or tile joints. Panels shall be secured to pilasters with brackets matching the wall brackets.

NOTE: Select anchorage devices for types of wall construction as required.

Panels shall be secured to hollow plastered walls with toggle bolts using not less than 1/4-20 M6 (1/4-20) screws of the length required for the wall thickness. Toggle bolts shall have a load-carrying strength not less than 600 pounds 2700 newton per anchor.

Panels shall be secured to ceramic tile on hollow plastered walls or hollow concrete-masonry walls with toggle bolts using not less than 1/4-20 M6 (1/4-20) screws of the length required for the wall thickness. Toggle bolts shall have a load-carrying strength not less than 600 pounds 2700 newton per anchor.

Panels shall be secured to solid masonry or concrete with lead or brass expansion shields designed for use with not less than 1/4-20 M6 (1/4-20) screws, with a shield length of not less than 1-1/2 inches. 40 millimeter. Expansion shields shall have a load-carrying strength not less than 600 pounds 2700 newton per anchor.

Installation Drawings shall be submitted for toilet partitions and urinal screens. Drawings shall indicate the type of partition, location, mounting height, cutouts, and reinforcement required for toilet-room accessories.

3.2 CEILING-HUNG PARTITIONS

NOTE: Delete the paragraph heading and the following paragraph if ceiling-hung partitions are not required. Coordinate the installation with the respective section for structural supports.

Pilasters shall be secured to supporting structural framing using pilaster hangers. Pilaster hangers shall not transmit the load to finished ceiling. Installation shall be plumbed, tightened, and leveled. Pilaster shoes shall be secured in position. Bottoms of doors shall be set level with bottoms of pilasters when they are in a closed position.

3.3 OVERHEAD-BRACED PARTITIONS

NOTE: Delete the paragraph heading and the following paragraph if overhead-braced partitions

are not required.

Pilasters shall be attached to the supporting floor with pilaster supports. Expansion shields shall have a minimum 2-inch 50 millimeter penetration into the concrete slab. Installation shall be plumbed, tightened, and leveled. Pilaster shoes shall be secured in place. Overhead brace shall be secured to pilaster face with not less than two fasteners per face. Tops of doors shall be set parallel with overhead braces when in a closed position.

3.4 FLOOR-SUPPORTED PARTITIONS

NOTE: Delete the paragraph heading and the following paragraph if floor-supported partitions are not required.

Pilasters shall be secured to the supporting floor with pilaster supports. Expansion shields shall have a minimum 2-inch 50 millimeter penetration into the concrete slab. Installation shall be plumbed, leveled, and tightened. Pilaster shoes shall be secured in position. Tops of doors shall be set level with tops of pilasters when in a closed position.

3.5 WALL-MOUNTED PARTITIONS

NOTE: Delete the paragraph heading and the following paragraph if wall-mounted partitions are not required. Coordinate the installation with the respective sections for structural supports.

Partitions shall be attached to walls with anchoring devices and wall brackets. Units shall be plumbed, leveled, and tightened. Tops of doors shall be set level with tops of pilasters when in a closed position.

3.6 SCREENS

NOTE: Delete the paragraph heading and the following paragraphs if screens are not required.

Select the type of screen required.

3.6.1 Entrance Screens

Screens shall be fabricated with the same types of panels, pilasters, and fittings as the toilet partitions.

3.6.2 Urinal Screens

Screens shall be fabricated with the same types of panels and pilasters as the toilet partitions. Fittings and fasteners shall be corrosion-resistant steel.

[Screens shall be wall hung with mounting brackets.]

[Screens shall be wall hung with flanges.]

[Screens shall be ceiling hung.]

[Screens shall be floor supported.]

[Screens shall be floor-to-ceiling post supported.]

3.7 FINAL ADJUSTMENTS AND INSPECTION

3.7.1 Adjustment

NOTE: Delete inapplicable paragraphs.

Hardware shall be adjusted and lubricated for proper operation after installation. Hinges for inward-swing doors shall be set to hold doors open approximately 30 degrees from the closed position when unlatched.

Hinges for outward-swing doors shall be set to hold doors open approximately 10 degrees from the closed position when unlatched.

Final adjustments shall be made to leveling devices and hardware.

3.7.2 Inspection

Partitions and doors shall be installed in the proper location and in correct alignment. Completed installation shall be rigid and substantially connected.

Hardware fittings and component parts shall be installed in accordance with approved drawings.

Partitions, pilasters, and doors shall be free of delaminations.

Door hinges and latches shall operate smoothly. Unlatched doors shall stop in the required position.

3.8 ACCEPTANCE PROVISIONS

3.8.1 Repairing

Damaged and unacceptable portions of completed work shall be removed and replaced with new work.

3.8.2 Cleaning

Surfaces of the work, and adjacent surfaces soiled as a result of the work, shall be cleaned in an approved manner. Equipment, surplus materials, and rubbish from the work shall be removed from the site.

-- End of Section --